

REPORT OF DRINKING WATER SAMPLING FOR LEAD CONTENT:

**ECE CENTRAL
15955 NEW HALLS FERRY ROAD
FLORISSANT, MO 63031**



PREPARED FOR:

**MR. DAVID DUDLEY
DIRECTOR OF MAINTENANCE
HAZELWOOD SCHOOL DISTRICT
15875 NEW HALLS FERRY RD
FLORISSANT, MISSOURI 63031**

PREPARED BY:

**ENPAQ, LLC
3130 GRAVOIS AVENUE
ST. LOUIS, MISSOURI 63139**

JULY 2023

DOCUMENT TO BE RETAINED INDEFINITELY

TABLE OF CONTENTS

23-170

Drinking Water Sampling for Lead

Hazelwood School District

ECE Central

15955 New Halls Ferry Road

Florissant, MO 63031

EXECUTIVE SUMMARY

APPENDIX A Sample Locations/Results

APPENDIX B Laboratory Analysis

APPENDIX C Credentials

EXECUTIVE SUMMARY

ENPAQ, LLC performed lead testing of multiple drinking fountain water sources at the Central Early Childhood Education located at 15955 New Halls Ferry Road in Florissant, Missouri. The sampling was performed by trained and licensed personnel in accordance with USEPA, HUD, and State of Missouri Regulations and Guidelines.

All inspectors involved with sampling activities had EPA-approved training in Lead. Credentials for our firm and the inspector collecting the samples are included in Attachment C to this document.

All samples were collected on a “first draw” basis. “First draw” is achieved by allowing the water system to rest for at least eight hours prior to sampling in order to collect any existing debris or settlement within the sample. The intent of this sampling is to replicate “worst-case scenario” conditions. As such, ENPAQ inspectors met at the school to collect water samples before the systems were used by staff or students. A second sample from each water source was collected as a “follow-up” sample basis. “Follow-up” sampling is achieved by allowing the water system to run for thirty (30) seconds after the first draw sampling. The intent of this sampling is to determine if lead contamination may be in the water lines connected to the water sources and not just at the fixture. The sampling was completed in accordance with the Missouri SB681 *Get the Lead Out of Schools Drinking Water Act* requirements. The Missouri SB681 *Get the Lead Out of Schools Drinking Water Act* and other regulatory agencies recommend that water sources run for at least thirty seconds and as long as two minutes prior to use to avoid settling within the water system.

Drinking water samples were collected from nineteen (19) different locations throughout Central Early Childhood Education during the sampling event. The water samples were collected from drinking fountains utilized for drinking activities at the campus. After sample collection, samples were immediately delivered to Teklab, Inc. located in Collinsville, Illinois following strict chain of custody procedures. Teklab is a NELAP-accredited and State of Missouri-licensed laboratory specializing in drinking water analysis. Detailed sampling locations and sample results are located in Attachment A of this report.

Any samples reported over 5.0 ppb should be re-sampled on an annual basis at a minimum.

The following results require written notification per the Missouri SB681 *Get the Lead Out of Schools Drinking Water Act* for samples reported above 5.0 ppb.

“First Draw” Sampling

Sample ID 02A	Kitchen Dishwashing Sink- Right	(1.5 ppb)
----------------------	--	------------------

“Follow-Up” Sampling

Sample ID 02B	Kitchen Dishwashing Sink- Right	(57.0 ppb)
----------------------	--	-------------------

CONCLUSION/RECOMMENDATIONS

At this time, ENPAQ recommends that all water sources testing at 5.0 ppb or above be removed from service. These sources are subject to additional maintenance activities and remediation prior to use. Before being put back into service, it is recommended these sources be re-tested to confirm compliance with acceptable levels.

Remediation includes decreasing lead concentrations below 5 parts per billion using methods such as replacement of plumbing, solder, fittings, or fixtures, installation of filters and filter devices, or other effective methods in accordance with Missouri SB681 *Get the Lead Out of Schools Drinking Water Act*.

In addition, all sources will be subject to an ongoing maintenance program and re-testing at appropriate intervals. **Any samples reported over 5.0 ppb should be re-sampled on an annual basis at a minimum.**

Although no additional samples were identified above the action level, ENPAQ recommends that all water sources run for at least thirty seconds prior to use as recommended by the USEPA.

APPENDIX A

SAMPLE LOCATIONS & RESULTS

Prep Day: 7/20/23

Sample Day: 7/21/23

To Lab -----> 7/21/23

* Reporting Limit

# Disabled =	0
# of Samples =	38
# > 10.0 ppb =	1
# > 0.5 ppb =	0

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
01	(A)	S	Kitchen Dishwashing Sink- Left		1.0	<1.0 ppb
	(B)	S	Kitchen Dishwashing Sink- Left		1.0	<1.0 ppb
	(C)				1.0	ppb
02	(A)	S	Kitchen Dishwashing Sink- Right		1.0	1.5 ppb
	(B)	S	Kitchen Dishwashing Sink- Right		1.0	57.0 ppb
03	(A)	S	Lounge Area Across From Room 13		1.0	<1.0 ppb
	(B)	S	Lounge Area Across From Room 13		1.0	<1.0 ppb
04	(A)	F	Fountain Across From Room 9		1.0	<1.0 ppb
	(B)	F	Fountain Across From Room 9		1.0	<1.0 ppb
05	(A)	F	Across From Room C- Left		1.0	<1.0 ppb
	(B)	F	Across From Room C- Left		1.0	<1.0 ppb
06	(A)	F	Across From Room C- Center		1.0	<1.0 ppb
	(B)	F	Across From Room C- Center		1.0	<1.0 ppb
07	(A)	F	Across From Room C- Right		1.0	<1.0 ppb
	(B)	F	Across From Room C- Right		1.0	<1.0 ppb
08	(A)	F	Near Galactic Office- Left		1.0	<1.0 ppb
	(B)	F	Near Galactic Office- Left		1.0	<1.0 ppb
09	(A)	F	Near Galactic Office- Right		1.0	<1.0 ppb
	(B)	F	Near Galactic Office- Right		1.0	<1.0 ppb
10	(A)	S	Galactic Nurses Sink		1.0	<1.0 ppb
	(B)	S	Galactic Nurses Sink		1.0	<1.0 ppb
11	(A)	F	Near Boardroom- Left		1.0	<1.0 ppb
	(B)	F	Near Boardroom- Left		1.0	<1.0 ppb

(Continuation Sheet)

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
12	(A)	F	Near Boardroom- Left Center		1.0	<1.0 ppb
	(B)	F	Near Boardroom- Left Center		1.0	<1.0 ppb
13	(A)	F	Near Boardroom- Center		1.0	<1.0 ppb
	(B)	F	Near Boardroom- Center		1.0	<1.0 ppb
14	(A)	F	Near Boardroom- Right Center		-	<1.0 ppb
	(B)	F	Near Boardroom- Right Center		-	<1.0 ppb
15	(A)	F	Near Boardroom- Right		1.0	<1.0 ppb
	(B)	F	Near Boardroom- Right		1.0	<1.0 ppb
16	(A)	S	Superintendent Break Room Sink		1.0	<1.0 ppb
	(B)	S	Superintendent Break Room Sink		1.0	<1.0 ppb
17	(A)	F	Near Admin Womens Restroom		1.0	<1.0 ppb
	(B)	F	Near Admin Womens Restroom		1.0	<1.0 ppb
18	(A)	S	Sink in Admin Lounge		1.0	<1.0 ppb
	(B)	S	Sink in Admin Lounge		1.0	<1.0 ppb
19	(A)	F	Near Admin Mens Restroom		1.0	<1.0 ppb
	(B)	F	Near Admin Mens Restroom		1.0	<1.0 ppb

Sample ID Coding Key:


F = Fountain

S = Sink

(A) = 1st Sample

(B) = 2nd Sample (30 Seconds Later)

(C) = 3rd Sample (3 Minutes Later)



1ST FLOOR PLAN

ADMINISTRATION / EARLY CHILDHOOD

HAZELWOOD SCHOOL DISTRICT, ST. LOUIS COUNTY, MISSOURI
21-100
03-09-2021

APPENDIX B

LABORATORY ANALYSIS

September 05, 2023

Tony Hagerty
ENPAQ, LLC
3130 Gravois Ave
St. Louis, MO 63118
TEL: (314) 449-1976
FAX:



Illinois	100226
Kansas	E-10374
Louisiana	05002
Louisiana	05003
Oklahoma	9978

RE: Hazelwood SD/ 23-170 ECE Central

WorkOrder: 23071513

Dear Tony Hagerty:

TEKLAB, INC received 38 samples on 7/21/2023 11:04:00 AM for the analysis presented in the following report.

Samples are analyzed on an as received basis unless otherwise requested and documented. The sample results contained in this report relate only to the requested analytes of interest as directed on the chain of custody. NELAP accredited fields of testing are indicated by the letters NELAP under the Certification column. Unless otherwise documented within this report, Teklab Inc. analyzes samples utilizing the most current methods in compliance with 40CFR. All tests are performed in the Collinsville, IL laboratory unless otherwise noted in the Case Narrative.

All quality control criteria applicable to the test methods employed for this project have been satisfactorily met and are in accordance with NELAP except where noted. The following report shall not be reproduced, except in full, without the written approval of Teklab, Inc.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,



Marvin L. Darling
Project Manager
(618)344-1004 ex 41
mdarling@teklabinc.com



Report Contents

<http://www.teklabinc.com/>

Client: ENPAQ, LLC

Work Order: 23071513

Client Project: Hazelwood SD/ 23-170 ECE Central

Report Date: 05-Sep-23

This reporting package includes the following:

Cover Letter	1
Report Contents	2
Definitions	3
Case Narrative	5
Accreditations	6
Laboratory Results	7
Receiving Check List	8
Chain of Custody	Appended

Client: ENPAQ, LLC**Work Order:** 23071513**Client Project:** Hazelwood SD/ 23-170 ECE Central**Report Date:** 05-Sep-23**Abbr Definition**

* Analytes on report marked with an asterisk are not NELAP accredited

CCV Continuing calibration verification is a check of a standard to determine the state of calibration of an instrument between recalibration.

CRQL A Client Requested Quantitation Limit is a reporting limit that varies according to customer request. The CRQL may not be less than the MDL.

DF Dilution factor is the dilution performed during analysis only and does not take into account any dilutions made during sample preparation. The reported result is final and includes all dilution factors.

DNI Did not ignite

DUP Laboratory duplicate is a replicate aliquot prepared under the same laboratory conditions and independently analyzed to obtain a measure of precision.

ICV Initial calibration verification is a check of a standard to determine the state of calibration of an instrument before sample analysis is initiated.

IDPH IL Dept. of Public Health

LCS Laboratory control sample is a sample matrix, free from the analytes of interest, spiked with verified known amounts of analytes and analyzed exactly like a sample to establish intra-laboratory or analyst specific precision and bias or to assess the performance of all or a portion of the measurement system.

LCSD Laboratory control sample duplicate is a replicate laboratory control sample that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MBLK Method blank is a sample of a matrix similar to the batch of associated sample (when available) that is free from the analytes of interest and is processed simultaneously with and under the same conditions as samples through all steps of the analytical procedures, and in which no target analytes or interferences should present at concentrations that impact the analytical results for sample analyses.

MDL "The method detection limit is defined as the minimum measured concentration of a substance that can be reported with 99% confidence that the measured concentration is distinguishable from method blank results."

MS Matrix spike is an aliquot of matrix fortified (spiked) with known quantities of specific analytes that is subjected to the entire analytical procedures in order to determine the effect of the matrix on an approved test method's recovery system. The acceptable recovery range is listed in the QC Package (provided upon request).

MSD Matrix spike duplicate means a replicate matrix spike that is prepared and analyzed in order to determine the precision of the approved test method. The acceptable recovery range is listed in the QC Package (provided upon request).

MW Molecular weight

NC Data is not acceptable for compliance purposes

ND Not Detected at the Reporting Limit

NELAP NELAP Accredited

PQL Practical quantitation limit means the lowest level that can be reliably achieved within specified limits of precision and accuracy during routine laboratory operation conditions.

RL The reporting limit the lowest level that the data is displayed in the final report. The reporting limit may vary according to customer request or sample dilution. The reporting limit may not be less than the MDL.

RPD Relative percent difference is a calculated difference between two recoveries (ie. MS/MSD). The acceptable recovery limit is listed in the QC Package (provided upon request).

SPK The spike is a known mass of target analyte added to a blank sample or sub-sample; used to determine recovery deficiency or for other quality control purposes.

Surr Surrogates are compounds which are similar to the analytes of interest in chemical composition and behavior in the analytical process, but which are not normally found in environmental samples.

TIC Tentatively identified compound: Analytes tentatively identified in the sample by using a library search. Only results not in the calibration standard will be reported as tentatively identified compounds. Results for tentatively identified compounds that are not present in the calibration standard, but are assigned a specific chemical name based upon the library search, are calculated using total peak areas from reconstructed ion chromatograms and a response factor of one. The nearest Internal Standard is used for the calculation. The results of any TICs must be considered estimated, and are flagged with a "T". If the estimated result is above the calibration range it is flagged "ET"

TNTC Too numerous to count (> 200 CFU)

Client: ENPAQ, LLC

Work Order: 23071513

Client Project: Hazelwood SD/ 23-170 ECE Central

Report Date: 05-Sep-23

Qualifiers

- | | |
|---|--|
| # - Unknown hydrocarbon | B - Analyte detected in associated Method Blank |
| C - RL shown is a Client Requested Quantitation Limit | E - Value above quantitation range |
| H - Holding times exceeded | I - Associated internal standard was outside method criteria |
| J - Analyte detected below quantitation limits | M - Manual Integration used to determine area response |
| ND - Not Detected at the Reporting Limit | R - RPD outside accepted recovery limits |
| S - Spike Recovery outside recovery limits | T - TIC(Tentatively identified compound) |
| X - Value exceeds Maximum Contaminant Level | |



Case Narrative

<http://www.teklabinc.com/>

Client: ENPAQ, LLC

Work Order: 23071513

Client Project: Hazelwood SD/ 23-170 ECE Central

Report Date: 05-Sep-23

Cooler Receipt Temp: N/A °C

Locations

Collinsville

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email jhriley@teklabinc.com

Collinsville Air

Address 5445 Horseshoe Lake Road
Collinsville, IL 62234-7425
Phone (618) 344-1004
Fax (618) 344-1005
Email EHurley@teklabinc.com

Springfield

Address 3920 Pintail Dr
Springfield, IL 62711-9415
Phone (217) 698-1004
Fax (217) 698-1005
Email KKlostermann@teklabinc.com

Chicago

Address 1319 Butterfield Rd.
Downers Grove, IL 60515
Phone (630) 324-6855
Fax
Email arenner@teklabinc.com

Kansas City

Address 8421 Nieman Road
Lenexa, KS 66214
Phone (913) 541-1998
Fax (913) 541-1998
Email jhriley@teklabinc.com

Client: ENPAQ, LLC**Work Order:** 23071513**Client Project:** Hazelwood SD/ 23-170 ECE Central**Report Date:** 05-Sep-23

State	Dept	Cert #	NELAP	Exp Date	Lab
Illinois	IEPA	100226	NELAP	1/31/2024	Collinsville
Kansas	KDHE	E-10374	NELAP	4/30/2024	Collinsville
Louisiana	LDEQ	05002	NELAP	6/30/2024	Collinsville
Louisiana	LDEQ	05003	NELAP	6/30/2024	Collinsville
Oklahoma	ODEQ	9978	NELAP	8/31/2023	Collinsville
Arkansas	ADEQ	88-0966		3/14/2024	Collinsville
Illinois	IDPH	17584		5/31/2025	Collinsville
Iowa	IDNR	430		6/1/2024	Collinsville
Kentucky	UST	0073		1/31/2024	Collinsville
Missouri	MDNR	00930		5/31/2023	Collinsville
Missouri	MDNR	930		1/31/2025	Collinsville



Laboratory Results

<http://www.teklabinc.com/>

Client: ENPAQ, LLC

Work Order: 23071513

Client Project: Hazelwood SD/ 23-170 ECE Central

Report Date: 05-Sep-23

Matrix: DRINKING WATER

Sample ID	Client Sample ID	Certification	Qual	RL	Result	Units	DF	Date Analyzed	Date Collected
EPA 600 4.1.4, 200.8 R5.4, METALS BY ICPMS (TOTAL)									
Lead									
23071513-001A	01 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 18:48	07/21/2023 0:00
23071513-002A	01 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 18:52	07/21/2023 0:00
23071513-003A	02 A	NELAP		1.0	1.5	µg/L	1	08/25/2023 18:56	07/21/2023 0:00
23071513-004A	02 B	NELAP		1.0	57.0	µg/L	5	08/21/2023 2:18	07/21/2023 0:00
23071513-005A	03 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 19:01	07/21/2023 0:00
23071513-006A	03 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 19:05	07/21/2023 0:00
23071513-007A	04 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 19:10	07/21/2023 0:00
23071513-008A	04 B	NELAP		1.0	< 1.0	µg/L	1	08/29/2023 11:05	07/21/2023 0:00
23071513-009A	05 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 19:50	07/21/2023 0:00
23071513-010A	05 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 19:55	07/21/2023 0:00
23071513-011A	06 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 19:59	07/21/2023 0:00
23071513-012A	06 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 13:43	07/21/2023 0:00
23071513-013A	07 A	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 13:48	07/21/2023 0:00
23071513-014A	07 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 13:57	07/21/2023 0:00
23071513-015A	08 A	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 13:52	07/21/2023 0:00
23071513-016A	08 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:23	07/21/2023 0:00
23071513-017A	09 A	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:28	07/21/2023 0:00
23071513-018A	09 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:32	07/21/2023 0:00
23071513-019A	10 A	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:37	07/21/2023 0:00
23071513-020A	10 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:41	07/21/2023 0:00
23071513-021A	11 A	NELAP		1.0	< 1.0	µg/L	5	08/21/2023 2:23	07/21/2023 0:00
23071513-022A	11 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:46	07/21/2023 0:00
23071513-023A	12 A	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 14:50	07/21/2023 0:00
23071513-024A	12 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 15:22	07/21/2023 0:00
23071513-025A	13 A	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 15:26	07/21/2023 0:00
23071513-026A	13 B	NELAP		1.0	< 1.0	µg/L	1	08/28/2023 15:31	07/21/2023 0:00
23071513-027A	14 A	NELAP		1.0	< 1.0	µg/L	1	09/01/2023 11:19	07/21/2023 0:00
23071513-028A	14 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 22:45	07/21/2023 0:00
23071513-029A	15 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 22:50	07/21/2023 0:00
23071513-030A	15 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 22:54	07/21/2023 0:00
23071513-031A	16 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 22:59	07/21/2023 0:00
23071513-032A	16 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 17:54	07/21/2023 0:00
23071513-033A	17 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 17:58	07/21/2023 0:00
23071513-034A	17 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 18:03	07/21/2023 0:00
23071513-035A	18 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 18:07	07/21/2023 0:00
23071513-036A	18 B	NELAP		1.0	< 1.0	µg/L	1	08/29/2023 10:46	07/21/2023 0:00
23071513-037A	19 A	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 18:12	07/21/2023 0:00
23071513-038A	19 B	NELAP		1.0	< 1.0	µg/L	1	08/25/2023 18:43	07/21/2023 0:00



Receiving Check List

<http://www.teklabinc.com/>

Client: ENPAQ, LLC

Work Order: 23071513

Client Project: Hazelwood SD/ 23-170 ECE Central

Report Date: 05-Sep-23

Carrier: Employee

Received By: MBP

Completed by:

Reviewed by:

On:

On:

21-Jul-23

21-Jul-23

Lindsey Maddox

Ellie Hopkins

Pages to follow: Chain of custody

4

Extra pages included

6

Shipping container/cooler in good condition?

Yes ☒

No ☐

Not Present ☐

Temp °C N/A

Type of thermal preservation?

None ☒

Ice ☐

Blue Ice ☐

Dry Ice ☐

Chain of custody present?

Yes ☒

No ☐

Chain of custody signed when relinquished and received?

Yes ☒

No ☐

Chain of custody agrees with sample labels?

Yes ☒

No ☐

Samples in proper container/bottle?

Yes ☒

No ☐

Sample containers intact?

Yes ☒

No ☐

Sufficient sample volume for indicated test?

Yes ☒

No ☐

All samples received within holding time?

Yes ☒

No ☐

Reported field parameters measured:

Field ☐

Lab ☐

NA ☒

Container/Temp Blank temperature in compliance?

Yes ☒

No ☐

When thermal preservation is required, samples are compliant with a temperature between 0.1°C - 6.0°C, or when samples are received on ice the same day as collected.

Water – at least one vial per sample has zero headspace?

Yes ☐

No ☐

No VOA vials ☒

Water - TOX containers have zero headspace?

Yes ☐

No ☐

No TOX containers ☒

Water - pH acceptable upon receipt?

Yes ☒

No ☐

NA ☐

NPDES/CWA TCN interferences checked/treated in the field?

Yes ☐

No ☐

NA ☒

Any No responses must be detailed below or on the COC.

Samples were checked for turbidity and then preserved with nitric acid upon arrival in the laboratory. - lmaddox - 7/21/2023 2:26:01 PM

Pg ___ of ___ Workorder # 23071513

Client: ENPAQ, LLC
Address: 3130 Gravois Ave.
City/State/Zip: Collinsville, IL 62234
Contact: Anthony Hagerty Phone: (314) 449-1976
Email: tony.hagerty@enpaqconsulting.com Fax: _____

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C
Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY
LAB NOTES:

Client Comments: ECE Central
Please Report in PPB

Are these samples known to be involved in litigation? If yes, a surcharge will apply: ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: ☒ Yes ☐ No

PROJECT NAME/NUMBER
Hazelwood SD/ 23-170

SAMPLE COLLECTOR'S NAME

Anthony Platt

RESULTS REQUESTED

☒ Standard
 ☐ 1-2 Day (100% Surcharge)
 ☐ Other
 ☐ 3 Day (50% Surcharge)

BILLING INSTRUCTIONS

and Type of Containers

INDICATE ANALYSIS REQUESTED

[illegible]

Lab Use Only	Sample ID	Date/Time Sampled	Matrix
23071513	001	7/21/23	Aqueous
	012		Aqueous
	013		Aqueous
	014		Aqueous
	015		Aqueous
	016		Aqueous
	017		Aqueous
	018		Aqueous
	019		Aqueous
	020		Aqueous
			Aqueous

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/21/23	<i>[Signature]</i>	7/21/23 1104

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

Pg ___ of ___ Workorder # 23071513

Client: ENPAQ, LLC
Address: 3130 Gravois Ave.
City/State/Zip: Collinsville, IL 62234
Contact: Anthony Hagerty Phone: (314) 449-1976
Email: tony.hagerty@enpaqconsulting.com Fax: _____

Samples on: ☐ ICE ☐ BLUE ICE ☐ NO ICE _____ °C

Preserved in: ☐ LAB ☐ FIELD FOR LAB USE ONLY

LAB NOTES:

Client Comments: ECE Central

Please Report in PPB

Are these samples known to be involved in litigation? If yes, a surcharge will apply: ☐ Yes ☒ No

Are these samples known to be hazardous? ☐ Yes ☒ No

Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: ☒ Yes ☐ No

PROJECT NAME/NUMBER

Hazelwood SD/ 23-170

SAMPLE COLLECTOR'S NAME

RESULTS REQUESTED

☒ Standard
 ☐ 1-2 Day (100% Surcharge)
 ☐ Other
 ☐ 3 Day (50% Surcharge)

BILLING INSTRUCTIONS

and Type of Containers

INDICATE ANALYSIS REQUESTED

[illegible]

Lab Use Only	Sample ID	Date/Time Sampled	Matrix
73071513 -021	11A	7/21/23	Aqueous
-022	11B		Aqueous
023	12A		Aqueous
024	12B		Aqueous
025	13A		Aqueous
026	13B		Aqueous
027	14A		Aqueous
028	14B		Aqueous
029	15A		Aqueous
030	15B		Aqueous
			Aqueous

Relinquished By	Date/Time	Received By	Date/Time
<i>[Signature]</i>	7/21/23	<i>[Signature]</i>	7/21/23 1104

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

INDEX

Pg ____ of ____ Workorder # 25071513

TEKLAB INC, 5445 Horseshoe Lake Road, Collinsville, IL 62234 Phone (618) 344-1004 Fax (618) 344-1005

Client: ENPAQ, LLC Address: 3130 Gravois Ave. City/State/Zip: Collinsville, IL 62234 Contact: Anthony Hagerty Phone: (314) 449-1976 Email: tony.hagerty@enpaqconsulting.com Fax:				Samples on: <input type="checkbox"/> ICE <input type="checkbox"/> BLUE ICE <input type="checkbox"/> NO ICE °C Preserved in: <input type="checkbox"/> LAB <input type="checkbox"/> FIELD <u>FOR LAB USE ONLY</u> LAB NOTES: Client Comments: ECE Central Please Report in PPB															
Are these samples known to be involved in litigation? If yes, a surcharge will apply: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are these samples known to be hazardous? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Are there any required reporting limits to be met on the requested analysis?. If yes, please provide limits in the comment section: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																			
PROJECT NAME/NUMBER Hazelwood SD/ 23-170				SAMPLE COLLECTOR'S NAME <i>Anthony Hagerty</i>				# and Type of Containers				INDICATE ANALYSIS REQUESTED							
RESULTS REQUESTED <input checked="" type="checkbox"/> Standard <input type="checkbox"/> 1-2 Day (100% Surcharge) <input type="checkbox"/> Other _____ <input type="checkbox"/> 3 Day (50% Surcharge)				BILLING INSTRUCTIONS				UNP HNO3 NaOH H2SO4 HCL MeOH NaHSO4 TSP Other											
Lab Use Only		Sample ID		Date/Time Sampled		Matrix													
B071513 DSI		16 A		7/21/23		Aqueous		X											
D32		16 B				Aqueous													
D33		17 A				Aqueous													
D34		17 B				Aqueous													
D35		18 A				Aqueous													
D36		18 B				Aqueous													
D37		19 A				Aqueous													
D38		19 B				Aqueous													
						Aqueous													
						Aqueous													
						Aqueous													
Relinquished By <i>[Signature]</i>				Date/Time 7/21/23				Received By <i>[Signature]</i>				Date/Time 7/21/23 1104							

*The individual signing this agreement on behalf of the client, acknowledges that he/she has read and understands the terms and conditions of this agreement, and that he/she has the authority to sign on behalf of the client. See www.teklabinc.com for terms and conditions

Prep Day: 7/20/23

Sample Day: 7/21/23

To Lab -----> 7/21/23

* Reporting Limit

to Test =
Disabled =
of Samples =
> 10.0 ppb =
> 0.5 ppb =

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
01	(A)	S	Kitchen Dishwashing Sink- Left		1.0	ppb
	(B)	S	Kitchen Dishwashing Sink- Left		1.0	ppb
	(C)				1.0	ppb
02	(A)	S	Kitchen Dishwashing Sink- Right		1.0	ppb
	(B)	S	Kitchen Dishwashing Sink- Right		1.0	ppb
03	(A)	S	Lounge Area Across From Room 13		1.0	ppb
	(B)	S	Lounge Area Across From Room 13		1.0	ppb
04	(A)	F	Fountain Across From Room 9		1.0	ppb
	(B)	F	Fountain Across From Room 9		1.0	ppb
05	(A)	F	Across From Room C- Left		1.0	ppb
	(B)	F	Across From Room C- Left		1.0	ppb
06	(A)	F	Across From Room C- Center		1.0	ppb
	(B)	F	Across From Room C- Center		1.0	ppb
07	(A)	F	Across From Room C- Right		1.0	ppb
	(B)	F	Across From Room C- Right		1.0	ppb
08	(A)	F	Near Galactic Office- Left		1.0	ppb
	(B)	F	Near Galactic Office- Left		1.0	ppb
09	(A)	F	Near Galactic Office- Right		1.0	ppb
	(B)	F	Near Galactic Office- Right		1.0	ppb
10	(A)	S	Galactic Nurses Sink		1.0	ppb
	(B)	S	Galactic Nurses Sink		1.0	ppb
11	(A)	F	Near Boardroom- Left		1.0	ppb
	(B)	F	Near Boardroom- Left		1.0	ppb

##

(Continuation Sheet)

23071515

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
12	(A)	F	Near Boardroom- Left Center		1.0	ppb
	(B)	F	Near Boardroom- Left Center		1.0	ppb
13	(A)	F	Near Boardroom- Center		1.0	ppb
	(B)	F	Near Boardroom- Center		1.0	ppb
14	(A)	F	Near Boardroom- Right Center		-	ppb
	(B)	F	Near Boardroom- Right Center		-	ppb
15	(A)	F	Near Boardroom- Right		1.0	ppb
	(B)	F	Near Boardroom- Right		1.0	ppb
16	(A)	S	Superintendent Break Room Sink		1.0	ppb
	(B)	S	Superintendent Break Room Sink		1.0	ppb
17	(A)	F	Near Admin Womens Restroom		1.0	ppb
	(B)	F	Near Admin Womens Restroom		1.0	ppb
18	(A)	S	Sink in Admin Lounge		1.0	ppb
	(B)	S	Sink in Admin Lounge		1.0	ppb
19	(A)	F	Near Admin Mens Restroom		1.0	ppb
	(B)	F	Near Admin Mens Restroom		1.0	ppb
20	(A)				1.0	ppb
	(B)				1.0	ppb
21	(A)				1.0	ppb
	(B)				1.0	ppb
22	(A)				1.0	ppb
	(B)				1.0	ppb
23	(A)				1.0	ppb
	(B)				1.0	ppb
24	(A)				1.0	ppb
	(B)				1.0	ppb
25	(A)				1.0	ppb
	(B)				1.0	ppb

##

(Continuation Sheet)

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
--------	-------------	-------------	-----------------	--------------	------	------------------

23071513

26	(A)				1.0	ppb
	(B)				1.0	ppb
27	(A)				1.0	ppb
	(B)				1.0	ppb
28	(A)				1.0	ppb
	(B)				1.0	ppb
29	(A)				-	ppb
	(B)				-	ppb
30	(A)				-	ppb
	(B)				-	ppb
31	(A)				2.0	ppb
	(B)				1.0	ppb
32	(A)				-	ppb
	(B)				-	ppb
33	(A)				1.0	ppb
	(B)				1.0	ppb
34	(A)				1.0	ppb
	(B)				1.0	ppb
35	(A)				1.0	ppb
	(B)				1.0	ppb
36	(A)				1.0	ppb
	(B)				1.0	ppb
37	(A)				1.0	ppb
	(B)				1.0	ppb
38	(A)				1.0	ppb
	(B)				1.0	ppb
39	(A)				1.0	ppb
	(B)				1.0	ppb

##

(Continuation Sheet)

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
40	(A)				1.0	ppb

23071513

	(B)			1.0	ppb
41	(A)			1.0	ppb
	(B)			1.0	ppb
42	(A)			1.0	ppb
	(B)			1.0	ppb
43	(A)			1.0	ppb
	(B)			1.0	ppb
44	(A)			1.0	ppb
	(B)			1.0	ppb
45	(A)			1.0	ppb
	(B)			1.0	ppb
46	(A)			1.0	ppb
	(B)			1.0	ppb
47	(A)			1.0	ppb
	(B)			1.0	ppb
48	(A)			1.0	ppb
	(B)			1.0	ppb
49	(A)			1.0	ppb
	(B)			1.0	ppb
50	(A)			1.0	ppb
	(B)			1.0	ppb
51	(A)			1.0	ppb
	(B)			1.0	ppb
52	(A)			1.0	ppb
	(B)			1.0	ppb
53	(A)			1.0	ppb
	(B)			1.0	ppb

##

(Continuation Sheet)

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
54	(A)				1.0	ppb
	(B)				1.0	ppb

23071513

55	(A)			1.0	ppb
	(B)			1.0	ppb
56	(A)			1.0	ppb
	(B)			1.0	ppb
57	(A)			1.0	ppb
	(B)			1.0	ppb
58	(A)			1.0	ppb
	(B)			1.0	ppb
59	(A)			1.0	ppb
	(B)			1.0	ppb
60	(A)			1.0	ppb
	(B)			1.0	ppb
61	(A)			1.0	ppb
	(B)			1.0	ppb
62	(A)			1.0	ppb
	(B)			1.0	ppb
63	(A)			1.0	ppb
	(B)			1.0	ppb
64	(A)			1.0	ppb
	(B)			1.0	ppb
65	(A)			1.0	ppb
	(B)			1.0	ppb
66	(A)			1.0	ppb
	(B)			1.0	ppb
67	(A)			1.0	ppb
	(B)			1.0	ppb

##

(Continuation Sheet)

Source	Sample ID #	Sample Type	Sample Location	Source Notes	RL *	Lead Test Result
68	(A)				1.0	ppb
	(B)				1.0	ppb

23071513

Sample ID Coding Key:

- F = Fountain
- S = Sink
- (A) = 1st Sample
- (B) = 2nd Sample (30 Seconds Later)
- (C) = 3rd Sample (3 Minutes Later)

APPENDIX C

CREDENTIALS

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

Lead Abatement Contractor License


The person, firm or corporation whose name appears on this certificate is licensed as a Lead Abatement Contractor as set forth in the Missouri Revised Statutes 701.300-701.338 and 19 CSR 30-70.180, as long as not suspended or revoked, and is hereby authorized to engage in lead-bearing substance activities.

Issued to:

ENPAQ, LLC

2321 Rutger Street, Unit F
St. Louis, MO 63104

Issuance Date: **2/10/2023**
Expiration Date: **2/26/2025**
License Number: **190226-004574**



Paula F. Nickelson

Paula F. Nickelson
Acting Director
Department of Health and Senior Services

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Anthony W. Hagerty

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **10/17/2022**
Expiration Date: **10/31/2024**
License Number: **161031-300005062**



Paula F. Nickelson

Paula F. Nickelson
Acting Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

COLLEGE FOR
PUBLIC HEALTH & SOCIAL JUSTICE
SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

Anthony Hagerty

3959 McDonald Ave, St. Louis, MO 63116

has attended 8 contact hours of training and successfully passed an examination

Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 325 - 3/7/2022 - 190510

Examination Date: 3/7/2022

CEUs: 0.8

Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health

Center for Environmental Education and Training, 3545 Lafayette, St. Louis, MO 63104
(314) 977-8256 slu.edu/x39753.xml

This training course has been accredited by the Illinois Department of Public Health, and by the Missouri Department of Health & Senior Services.

Christopher C. King
Christopher C. King PhD
Director, Center for Environmental
Education and Training

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

James T. Earle

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **7/30/2022**
Expiration Date: **7/30/2024**
License Number: **180730-300005561**



Paula F. Nickelson

Paula F. Nickelson
Acting Director
Department of Health and Senior Services

Lead Licensing Program, PO Box 570, Jefferson City, MO 65102

COLLEGE FOR
PUBLIC HEALTH & SOCIAL JUSTICE
SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

James Earle

7484 Ahern Ct., University City, MO 63130

has attended 8 contact hours of training and successfully passed an examination

Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 325 - 3/7/2022 - 117401
Examination Date: 3/7/2022
CEUs: 0.8

Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health

Center for Environmental Education and Training, 3545 Lafayette, St. Louis, MO 63104
(314) 977-8256 sltu.edu/x39753.xml

This training course has been accredited by the Illinois Department of Public Health, and by the Missouri Department of Health & Senior Services.

Christopher C. King
Christopher C. King PhD
Director, Center for Environmental
Education and Training

STATE OF MISSOURI
DEPARTMENT OF HEALTH AND SENIOR SERVICES

LEAD OCCUPATION LICENSE REGISTRATION

Issued to:

Zachary A. Haselhorst

The person, firm or corporation whose name appears on this certificate has fulfilled the requirements for licensure as set forth in the Missouri Revised Statutes 701.300-701.338, as long as not suspended or revoked, and is hereby authorized to engage in the activity listed below.

Lead Risk Assessor
Category of License

Issuance Date: **3/1/2022**
Expiration Date: **3/1/2024**
License Number: **160229-300004899**



A handwritten signature in black ink, appearing to read "Richard W. Moore", is positioned above the printed name.

Richard W. Moore
Acting Director
Department of Health and Senior Services

COLLEGE FOR
PUBLIC HEALTH & SOCIAL JUSTICE
SAINT LOUIS UNIVERSITY

CENTER FOR ENVIRONMENTAL EDUCATION AND TRAINING

verifies that

Zachary Haselhorst

209 E 5th St, Trenton, IL 62293

has attended 8 contact hours of training and successfully passed an examination

Lead Risk Assessor Refresher

St. Louis, MO

Certificate # CEET 325 - 3/7/2022 - 117400
Examination Date: 3/7/2022
CEUs: 0.8

Certificate expiration is 3 years from examination date for Illinois Dept. of Public Health

Center for Environmental Education and Training, 3545 Lafayette, St. Louis, MO 63104
(314) 977-8256 slu.edu/x39753.xml

This training course has been accredited by the Illinois Department of Public Health, and by the Missouri Department of Health & Senior Services.

Christopher C. King
Christopher C. King PhD
Director, Center for Environmental
Education and Training

State of Missouri
Department of Natural Resources

Certificate of Approval
for Chemical Laboratory Service

This is to certify that

Teklab, Incorporated

is hereby approved to perform the analysis of drinking water as specified on the
Certified Parameter List, which must accompany this certificate to be valid.

Certification Number 930

Date Issued December 13, 2021

Expiration Date January 31, 2025



Laboratory Certification Authority, Public Drinking Water Branch
Missouri Department of Natural Resources



Laboratory Certification Officer, Environmental Services Program
Missouri Department of Natural Resources

MISSOURI DEPARTMENT OF NATURAL RESOURCES
DRINKING WATER LABORATORY
CERTIFIED PARAMETER LIST

This is to certify that

Teklab, Incorporated

located at

5445 Horseshoe Lake Road, Collinsville, IL 62234

has been approved to perform the indicated procedures on drinking water under the Missouri Public Drinking Water Regulations (10 CSR 60-5.020). Specific method numbers or references are included in parenthesis when appropriate.

INORGANIC

EPA 335.4

Total Cyanide

EPA 353.2

Nitrate, Nitrite, Total Nitrate and Nitrite

EPA 245.1

Mercury

EPA 200.7

Barium, Beryllium, Cadmium, Chromium, Copper, Nickel

EPA 200.8

Antimony, Arsenic, Barium, Beryllium, Cadmium, Chromium, Copper, Lead, Nickel, Selenium, Thallium

SM4500F-C

Fluoride

SM4500NO2-B

Nitrite

Teklab, Incorporated

Expiration Date: January 31, 2025

Missouri Certificate No.: 930

Original Certifying State: Illinois